



December 15, 2021  
Reference: 522160

To  
Amit Abramovich  
Green ICPS Ltd

Re: **Product approval for use with drinking water**

Based on SII test certificate no. 7112203877 for complying  
with the requirements of SI 5452 (2016)

In accordance with the instructions of the Israeli Ministry of Health and after testing a representative sample of the product and receiving the relevant information for it, we have no objection to the use of a coating material type "Corrizon Base", made by "Green ICPS Ltd", Israel, in drinking water applications at a temperature of up to 40°C.

Any modification of the product or its composition requires further examination and re-approval.

This letter does not constitute a recommendation to use the mentioned product, and should not be published in the mass media.

This approval is valid until October 18, 2026.

Sincerely,  
Assaf Amram  
Head of Water section  
Chemistry, Food and Water Branch

***This document is not approval for marking the product with the Standards Mark***

The information in this approval will be published in "search engine drinking water SI 5452" on the SII site